

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:44 pm

PWS ID: UTAH23044 **Name:** S AND W TRAILER PARK
Legal Contact: S AND W TRAILER PARK **Rating:** Approved
VALENTINE E STEARNS **Rating Date:** 01/20/1986
Address: 9094 N HWY 40 **Activity Status:** Active
LAKEPOINT, UT 84074
Phone Number: 435-250-5296
City Served (Area):
County: TOOELE COUNTY
System Type: Community **Last Inv Update:** 04/26/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 05/25/2011 **Total Dsgn Cap:**
Population: 300 **Surveyor:** VICKIE ROLFE **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	STEARNS, VALENTINE E		435-250-9405	801-250-5296	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	1
			1 Total Svc Connections

Storage

Total Storage: 20,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST002	STEEL TANK ST002	Standpipe	20,000 GAL	Steel		A	NO
ST001	STORAGE FACILITY ST001	Standpipe	2,500 GAL	Concrete		I	NO

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
		No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	6	327 GPM	25 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL # 2	Inactive	WL	3			Yes	GW	Other		

*Reports measured flow for wells, approved design capacity for all other sources.